



Administration of Daman & Diu (U.T.),
Deptt. of Fire & Emergency services,
Fire Force Headquarters, Somnath,
Daman - 396 215.
Email: sfo-dmn-dd@nic.in

No. DFES/DMN/FNOC-Ren/384/ADFO/2017/

Dated: 15/05/2017.

To,

M/s. Karmasheel,
Survey No.A-3/16,
Somnath Industrial Estate,
Dabhel, Nani Daman.

Sub: Annual renewal of Fire No Objection Certificate of the factory building – reg.
Ref: 1. Your application dated 17/04/2017.
2. No. DFES/DMN/FNOC/2015-16/45 dated 17-08-2015.
3. Fire Safety Inspection report dated 21-04-2017.

Sir,

M/s. Karmasheel, Somnath, Nani Daman has re-applied for annual renewal of fire No-Objection Certificate of the factory building having on ground floor + mezzanine floor with total height of **5.10 meters** from the general ground level up to the terrace level on land bearing survey No.A-3/16 situated at village Somnath Industrial Estate, Dabhel, Nani Daman manufacturing of plastics bags.

The plan of the factory building plan is approved as per DCR-2005 by the competent authority as submitted by the applicant. As per approved plan of the factory building, the details of the construction and plot area are shown in the approved plan of the building is as under:

Sr. No.	Particulars of Construction	Total B/U area (Sq. M.)
01.	Total Plot area	820.00
	Permissible ground coverage @50 %	410.00
	Consumed ground coverage @46.48%	381.15
	Permissible F.S.I./FAR 1.00	820.00
	Consumed FAR/F.S.I. -0.54	445.302
02.	Existing built up area	
	Ground floor	381.15
	Mezzanine floor area	64.152
	TOTAL BUILT UP AREA	445.302
03.	Total height of the building in mtrs.	5.10

As per approved plan, the site abuts have internal roads about 10 meters wide on south side, as shown on the plan. Open space around the building from plot boundary as shown below.

Sides	Open spaces as per approved plan	Open spaces physically measured during the inspection on 21.04.2017.	Width of abuts road
North	03.90 Meters	03.65 Meters	--
South	04.00 Meters	04.00 Meters	+ 10 meters wide road
East	04.50 Meters	04.50 Meters	--
West	04.00 Meters	03.50 Meters	--

The said Industrial unit has inspected on **21/04/2017** by Shri Canji Narane, Station Fire Officer in presence of **Shri Sanjeev Joshi** and found that the fire fighting arrangements in satisfactory working condition at the time of inspection.

In view of the above, so far as department is concerned, there would be no objection for grant of further annual renewal of fire No Objection Certificate of the distillery building having on ground floor + mezzanine floor with total height of **5.10 meters** from the general ground level up to the terrace level on land bearing survey No.A-3/16 situated at village Somnath Industrial Estate, Dabhel, Nani Daman manufacturing of plastics bags subject to satisfactory compliance with the following basic fire fighting requirements of the National Building Code of India and as required under the Notification No.DFS/DD/F.P.-Notification/2004-05/627 dated 12-01-2005 issued under sub-section (1) of section 13 of the Goa, Daman and Diu Fire Force Act, 1986.

1. All the fire safety arrangements provided therein shall be maintained periodically and in good working condition at all times. If the said system is not maintained, retrenched, this N.O.C. will stand cancelled without any notice & you will be fully responsible to loss of life or property, if any, which may please be noted.
2. Courtyard all around the building should be always free from obstruction and encroachment for fire brigade access.
3. The storage, use and handling gasoline, fuel oil, explosive materials and other flammable liquid/gas shall not be permitted in any Group G occupancy unless it complies with the regulations and in the event of any violation; the (Owner/Occupier) of the said premises will be liable to be dealt with penal action.
4. No residential accommodation as well as canteen/kitchen should be provided in the industrial building in any circumstances.
5. The trained fire fighting staff should be available round the clock.
6. Any compartmentation in addition to the approved plan shall be made only prior approval of the fire department.
7. Any deviation with respect to construction etc. shall be verified by the concerned building sanctioning authority.
8. This fire NOC may not treated in any case for regularization of unauthorized construction, if any.
9. It shall be sole responsibility/duty of Management/Owner/ Occupier of the factory building to conduct safe evacuation drill/fire fighting drill periodically and shall be submitted the report with next renewal proposal.
10. The applicant shall apply for renewal of this fire NOC to this office before **two month** from the date of expired.
11. The undersigned reserves right to amend any additional recommendations deemed fit during final inspection or in future due to the statutory provisions


amended from time to time and in the interest of the protection of the company and employees.

12. Right to reject/withdrawn N.O.C. at any time without any notice is vested /reserved with the competent authority if the conditions stipulated above are not complied with.
13. This is issued for a period of one year from the date of issue and subject renewed from time to time failing which the same should be cancelled.

The applicant has paid the renewal fees to the tune of Rs. 2,500/- (Rupees Two thousand five hundred only) by Challan No. 14 dated 08-05-2017.

On breach of any of the above conditions, the department shall take punitive/penal action as per Notification No.DFS/DD/F.P.-Notification/2004-05/627 dated 12-01-2005 issued under sub-section (2) of section 13 of the Goa, Daman & Diu Fire Force Act, 1986 subject to compliance of the following conditions.

Yours faithfully,


Assistant Director,
Fire & Emergency Services,
Daman.

o/c gmt

Copy to:-

1. The General Manager, D.I.C., Daman.
2. The Associates Town Planner, Daman.
3. Office copy.

