



U.T. Administration of  
Dadra & Nagar Haveli and Daman & Diu,  
Deptt. of Fire & Emergency Services,  
Fire Force Headquarters, Daman,  
Daman - 396 215.  
E-Mail ID: [sfo-dmn-dd@nic.in](mailto:sfo-dmn-dd@nic.in).



F7S No:- 105

No. 45/08/FIRE-AUDIT/14-15/DFES/146

Dated: 31/05/2023.

- Read: 1. Notice No. DFES/DMN/Notice/865/ADFO/2019 dt.01/02/2019.  
2. Advisory Notice No. F-23019/1376/2019 dated 22/05/2019.  
3. Notice No.F-23019/1376/2019 dated 18/06/2019.  
4. Notice No. DFES/DMN/FIRE AUDIT/2014-15/131 dated 12/04/2021.  
5. No. DFES/DMN/FIRE AUDIT/2014-15/04 dated 13/01/2023.

## NOTICE

### FOR VIOLATION OF FIRE PREVENTION AND FIRE SAFETY MEASURES

WHEREAS, the Fire & Emergency Services, Daman & Diu had issued Notices dated 01/02/2019, 22/05/2019 and 18/06/2019, 12/04/2021 & 13/01/2023 as quoted at preambles 01, 02, 03, 04 and 05 above to apply for fire NOC and comply with the fire safety measures and to remove the encroachment /obstructions from the marginal open spaces (set back) in the premises within stipulated time limit. However, you have neither applied for fire NOC, nor removed the encroachments/ obstructions from the marginal open spaces till date.

AND WHEREAS, the Fire & Emergency Services, Daman had also issued fire safety recommendation to various Industrial units, Hotels, High-rise/ Residential-Cum Commercial, Educational Institutes/Schools, (Commercial building such as Shopping Malls, Theatres, Restaurant) and Business building, Hospitals buildings etc...for compliance of fire safety measures within stipulated time limit. However, they have neither applied for final fire NOC, nor complied with the appropriate fire safety measures as advised by the Fire department within stipulated time limit even till now.

AND WHEREAS, Fire department had also issued Final fire NOC to various Industrial units, Hotels, High-rise/ Residential-Cum Commercial, Educational Institutes/Schools, (Commercial building such as Shopping Malls, Theatres, Restaurant) and Business building, Hospitals buildings etc... subject to renewal of fire NOC. However, they have not applied for renew the fire NOC within stipulated time limit even till now. These are in clear violation of fire prevention and fire safety measures.


AND WHEREAS, while attending fire incidents in the recent past, it has come to notice that almost all Industrial units or any other occupancies have failed to keep open spaces (Set back) clear for passage as per approved plan. The open spaces have been stocked with various inventory materials, storage and structures have been found to be erected with plastic/tarpoline or iron sheet shed due to which the fire fighting vehicles cannot approach closer to the industrial structure. The plastic/tarpoline is fire prone materials as they form a bridge for easy spreading of fire within premises and in adjoining industrial units.



AND WHEREAS, a Notification No.DFS/DD/F.P-Notification/2004.05 / 627 dated 12-01-2005 issued under sub-section (1) of Section 13 of the Goa, Daman and Diu Fire Force Act, 1986 (Act 9 of 1986) and under rule 24 of Daman and Diu Fire Force Rules 2004, the factories and establishments, storage places of flammable and Hazardous goods, petroleum product, Industrial units, Hotels, High-rise/ Residential-Cum Commercial, Educational Institutes/Schools, (Commercial building such as Shopping Malls, Theatres, Restaurant) and Business building, Hospitals buildings etc...are required to take fire prevention and fire safety measures/installations of fire fighting requirement as provided National Building Code of India/General Development Rules-2023 and fire NOC is necessary for such places and trades.

This notice shall come into force from the date of issue of this notice. Since it is not possible to serve this notice individually, it is hereby issued ex-parte and shall be circulated in print, electronic and social media for the information of all concerned. Any violation of this behalf shall be dealt with under the relevant provisions of law.

NOW THEREFORE, you are once again directed to apply for the fire NOC and renewal of fire NOC, comply with the fire safety measures within 01 months from the date of receipt this notice and various inventory materials, storage and temporary structures erected in marginal open spaces may also be removed immediately as per approved plan for fire brigade access at all time failing which deemed fit action will be taken against defaulters in accordance of relevant Act & Rule which should be noted.

  
31/5/24  
(Milind Mahadeo Dumbere) IPS,  
IGP/Director,  
Fire & Emergency Services,  
DNH and Daman & Diu,  
Daman.

To,

All Industrial units, Hotels, High-rise/ Residential-Cum Commercial, Educational Institutes/Schools etc... of Daman & Diu.

Copy for necessary action to:-

1. PA to Adviser to Hon. Administrator, DNH and Daman & Diu.
2. The Secretary (Industries), DNH and Daman & Diu.
3. The Secretary (Urban Development), DNH and Daman & Diu.
4. The Secretary (Tourism), DNH and Daman & Diu.
5. The Secretary (Higher & Technical Education and School Education), DNH and Daman & Diu.
6. The Collector, Daman/Diu.
7. The General Manager, DIC, DNH and Daman & Diu.
8. The Associate Town Planner, PDA, Daman/Diu.
9. Office copy.